

## § 75.35

## 40 CFR Ch. I (7–1–12 Edition)

(1) Where monitor data availability for a NO<sub>x</sub> continuous emission monitoring system is 90.0 percent or more, the owner or operator may calculate substitute data using an approved parametric monitoring procedure.

(2) Where monitor data availability for a NO<sub>x</sub> continuous emission monitoring system is less than 90.0 percent, the owner or operator shall calculate substitute data using the procedure in § 75.34(a) (1) or (2), even if the Administrator has approved a parametric monitoring procedure.

(d) In order to implement the options in paragraphs (a)(1), (a)(3) and (a)(5) of this section; and §§ 75.31(c)(3) and 75.72(c)(3), the owner or operator shall keep records of information as described in § 75.58(b)(3) to verify the proper operation of all add-on SO<sub>2</sub> or NO<sub>x</sub> emission controls, during all periods of SO<sub>2</sub> or NO<sub>x</sub> emission missing data. If the owner or operator elects to implement the missing data option in paragraph (a)(2) of this section, the records in § 75.58(b)(3) are required to be kept only for the ozone season. The owner or operator shall document in the quality assurance/quality control (QA/QC) program required by section 1 of appendix B to this part, the parameters monitored and (as applicable) the ranges and combinations of parameters that indicate proper operation of the controls. The owner or operator shall provide the information recorded under § 75.58(b)(3) and the related QA/QC program information to the Administrator, to the EPA Regional Office, or to the appropriate State or local agency, upon request.

[60 FR 26567, May 17, 1995, as amended at 61 FR 59160, Nov. 20, 1996; 64 FR 28604, May 26, 1999; 67 FR 40438, June 12, 2002; 73 FR 4348, Jan. 24, 2008; 76 FR 17312, Mar. 28, 2011]

### § 75.35 Missing data procedures for CO<sub>2</sub>.

(a) The owner or operator of a unit with a CO<sub>2</sub> continuous emission monitoring system for determining CO<sub>2</sub> mass emissions in accordance with § 75.10 (or an O<sub>2</sub> monitor that is used to determine CO<sub>2</sub> concentration in accordance with appendix F to this part) shall substitute for missing CO<sub>2</sub> pollutant concentration data using the proce-

dures of paragraphs (b) and (d) of this section.

(b) During the first 720 quality-assured monitor operating hours following initial certification at a particular unit or stack location (*i.e.*, the date and time at which quality-assured data begins to be recorded by a CEMS at that location), or (when implementing these procedures for a previously certified CO<sub>2</sub> monitoring system) during the 720 quality-assured monitor operating hours preceding implementation of the standard missing data procedures in paragraph (d) of this section, the owner or operator shall provide substitute CO<sub>2</sub> pollutant concentration data or substitute CO<sub>2</sub> data for heat input determination, as applicable, according to the procedures in § 75.31(b).

(c) [Reserved]

(d) Upon completion of 720 quality-assured monitor operating hours using the initial missing data procedures of § 75.31(b), the owner or operator shall provide substitute data for CO<sub>2</sub> concentration or substitute CO<sub>2</sub> data for heat input determination, as applicable, in accordance with the procedures in § 75.33(b) except that the term “CO<sub>2</sub> concentration” shall apply rather than “SO<sub>2</sub> concentration,” the term “CO<sub>2</sub> pollutant concentration monitor” or “CO<sub>2</sub> diluent monitor” shall apply rather than “SO<sub>2</sub> pollutant concentration monitor,” and the term “maximum potential CO<sub>2</sub> concentration, as defined in section 2.1.3.1 of appendix A to this part” shall apply, rather than “maximum potential SO<sub>2</sub> concentration.”

[67 FR 40439, June 12, 2002]

### § 75.36 Missing data procedures for heat input rate determinations.

(a) When hourly heat input rate is determined using a flow monitoring system and a diluent gas (O<sub>2</sub> or CO<sub>2</sub>) monitor, substitute data must be provided to calculate the heat input whenever quality-assured data are unavailable from the flow monitor, the diluent gas monitor, or both. When flow rate data are unavailable, substitute flow rate data for the heat input rate calculation shall be provided according to § 75.31 or § 75.33, as applicable. When diluent gas